CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Mineral Fiber Blanket Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

KUWAIT INSULATING MATERIAL MANUFACTURING CO. (KIMMCO - ISOVER)

P.O. Box: 10042 Shuaiba, Kuwait

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

ASTM C553-2013

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).

For/ ENG. MAJED AL SHAMSI
Certification and Quality Control of Products Section's Manager
Dubai Central Laboratory Department-Dubai Municipality

CB-PRD-001

Certificate No: CL06020015-2
Valid Until: 27/01/2026

PRODUCT CONFORMITY

Current Issue Date: 28/01/2025
Original Issue Date: 28/01/2007

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL06020015-2

Certificate Issued To: **KUWAIT INSULATING MATERIALS MFG. CO. (KIMMCO - ISOVER)**
P.O. Box: 10042 Shuaiba, Kuwait

Applicable Standard Specification: **ASTM C 553: 2013** : Standard Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Application.

Applicable Specific Rules: **DM-DCLD-RD-DP21-2109** (IC): Certification of Mineral Fiber Blanket Insulation as per ASTM C 553-13

S/N	PRODUCT DESCRIPTION	PRODUCT BRAND	PRODUCT DETAILS
1.	Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Application (CFC Free)[See Note 6]	KIMMCO-ISOVER Building Roll (KBR)	Type I without facing k-value: 0.056 W/(m-°K) Nominal Density: 10 kg/m³ Nominal Thickness: 25-150 mm
2.		KBR Smart KBR Smart Plus KBR Advance	Type II without facing k-value: 0.048 W/(m-°K) Nominal Density: 12 - 18 kg/m³ Nominal Thickness: 25-150 mm
3.		KBR Premium KBR Ultra	Type III without facing k-value: 0.040 W/(m-°K) Nominal Density: 20 - 48 kg/m³ Nominal Thickness: 25-150 mm
4.		KIMMCO-ISOVER Building Roll (KBR)	Type I with aluminum foil facing k-value: 0.056 W/(m-°K) Nominal Density: 10 kg/m³ Nominal Thickness: 25-150 mm

DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL06020015-2

5.	Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Application (CFC Free)[See Note 6]	KBR Smart KBR Smart Plus KBR Advance KBR Premium KBR Ultra	Type II with aluminum foil facing k-value: 0.048 W/(m-°K) Nominal Density: 12 - 18 kg/m³ Nominal Thickness: 25-150 mm
6.			Type III with aluminum foil facing k-value: 0.040 W/(m-°K) Nominal Density: 20 - 48 kg/m³ Nominal Thickness: 25-150 mm
7.			Type III with aluglass facing k-value: 0.040 W/(m-°K) Nominal Density: 20 - 48 kg/m³ Nominal Thickness: 25-150 mm
8.		KIMMCO-ISOVER Clean Liner (KCL)	Type III with black glass fabric facing k-value: 0.040 W/(m-°K) Nominal Density: 24-48 kg/m³ Nominal Thickness: 13-100 mm
9.		EcoBuild EBR Smart	Type I without facing k-value: 0.056 W/(m-°K) Nominal Density: 10 kg/m³ Nominal Thickness: 25-150 mm
10.		EcoBuild EBR Smart Plus EcoBuild EBR Advance	Type II without facing k-value: 0.048 W/(m-°K) Nominal Density: 12 - 18 kg/m³ Nominal Thickness: 25-150 mm
11.		EcoBuild EBR Premium EcoBuild EBR Supreme	Type III without facing k-value: 0.040 W/(m-°K) Nominal Density: 20 - 48 kg/m³ Nominal Thickness: 25-150 mm

DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL06020015-2

12.	Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Application (CFC Free)[See Note 6]	EcoBuild EBR Ultra	Type I with aluminum foil facing k-value: 0.056 W/(m-°K) Nominal Density: 10 kg/m³ Nominal Thickness: 25-150 mm
13.			Type II with aluminum foil facing k-value: 0.048 W/(m-°K) Nominal Density: 12 - 18 kg/m³ Nominal Thickness: 25-150 mm
14.			Type III with aluminum foil facing k-value: 0.040 W/(m-°K) Nominal Density: 20 - 48 kg/m³ Nominal Thickness: 25-150 mm
15.		ISOVER Eco Acoustic Partition Roll	Type II without facing k-value: 0.048 W/(m-°K) Nominal Density: 10 - 16 kg/m³ Nominal Thickness: 25-150 mm

DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL06020015-2

NOTE 1: This document forms an integral part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above product shall bear the DCLD Conformity Mark.

NOTE 3: Maximum k-value measured at 35ºC temperature and 60% relative humidity condition.

NOTE 4: As applicable, other properties in the product standard specification which were excluded in the specific rules as approved by the certification body authorized personnel are to be verified by the end user of the product (if needed).

Note 5: This scope does not cover the use of these products as Pipe & Duct Insulation materials

which as per the Al Sa'fat Dubai Green Building System is covered by DM-DCLD-RD-DP21-2185 (IC).

Note 6: In compliance with Al Sa'fat Dubai Green Building System.

Original Issue Date : 28-01-2007
Current Issue Date : 28-01-2025
Valid Until : 27-01-2026



For/ **ENG. MAJED AL SHAMSI**

CERTIFICATION AND QUALITY CONTROL OF PRODUCTS SECTION'S MANAGER